

**Details of Availability of Treated Waste Water**

Sr. No.	Name / location of STP	Status of STP	Level of treatment	GPCB Limit		Technology used for treatment	Co-ordinates of STP Latitude (in decimal degrees)	Co-ordinates of STP Longitude (in decimal degrees)	Installed capacity (MLD)	Average available quantity (MLD)
				BOD Mg/L	TSS Mg/L					
1	Gajrawadi / Sewage Pumping Station Road Gjarawadi	Working	Secondary	30	100	Activated Sludge	22°17'13.33"N	73°13'14.22"E	66	66
2	Tarsali / Sussen Tarsali Ring Road	Working	Secondary	20	30	Activated Sludge	22°15'32.34"N	73°13'12 "E	52	52
3	Atladara (OLD) / Munjmahuda, Padra Road	Working	Secondary	20	30	UASB, Gas based Power Genration	22°16'50.50"N	73°10'.08"E	43	43
4	Atladara (NEW) /Munjmahuda, Padra Road	Working	Secondary	20	30	UASB, Gas based Power Genration	22°16'49.54"N	73°10'05.91"E	43	43
5	Kapurai / Nr. Kapurai Village	Working	Secondary	30	100	UASB	22°16'16.31"N	73°15'41.74"E	43	43
6	Sayaji Garden	Working	Secondary	30	100	Extended Aeration	22°19'01"N	73°11'36.75"E	8.5	5
7	Chhani / Nr. Chhani Village	Working	Secondary	10	10	Extended Aeration	22°21'20.83"N	73°10'42.75"E	21	21
8	Rajivnagar / Rajivnagar New VIP Road	Working	Tertiary with media filtration	5	5	SBR with Tertiary Treatment	22°19'33.57"N	73°13'53.61"E	78	20